

## Hall A - SoLID Magnet Control Systems – Meeting Minutes

**Date:** March 11, 2020

**Time:** 10:00 – 11:00

Attendees: Pablo Campero and Steven Lassiter

### 1. Constant Current Source (CCS) boards

- 1.1. PCB boards received
- 1.2. Next step is the assembly and testing of the boards

### 2. PLC programming status

- 2.1. Implemented standard TvsR curves for PT100s and diodes temperature sensors located in the Heat Exchanger and CCR
  - 2.1.1. New changes in the code will be uploaded to the PLC controller
- 2.2. DSG is unable to launch RSLinx Classic on PHYCAD58 computer
  - 2.2.1. Reason: PHYCAD58 is running RSLinx Classic in Server Mode
  - 2.2.2. Addition of PLC I/O modules installation, if needed, will be handled by Steven Lassiter.
- 2.3. Steven Lassiter added Remote # 2 PLC chassis with the PLC I/O modules required

### 3. HMI programming status

- 3.1. Implemented requested modifications for the first version of *Axial and Radial Supports Expert* HMI screen
  - 3.1.1. Added color indicators to enable/disable buttons
  - 3.1.2. Combined “Ramp up/down limits” to be “Controlled ramp down thresholds”
  - 3.1.3. Added trend for individual signals
- 3.2. Developing *CCR Instrumentation* HMI screen
  - 3.2.1. Screen can be based on *HMS Dipole CCR*

### 4. Instrumentation status

- 4.1. Rack moved from TED room 1544 to Test Lab; now located at the left side of the magnet
  - 4.1.1. In preparation for population of the rack, there are some actions to be done:
    - 4.1.1.1. Pablo Campero will generate a parts list with all required material and components to be installed in the rack
    - 4.1.1.2. Check in hand components
    - 4.1.1.3. Order new components based on the generated parts list
- 4.2. Confirmed that CCS boards will be used to supply current to the two and three wire temperature sensors

### 5. Electrical drawings status

- 5.1. Agreed that any missed cable number, terminal strip number, and wiring color can be assigned by DSG
- 5.2. Completed electrical drawings will be reviewed and approved by Steven Lassiter

### 6. Discussed RSLogix 5000 licenses issues

- 6.1. PHYCAD58 computer appears to be using three of the four licenses (available in “cadlm2” server) even when RSLogix 5000 software is not open/running on it
- 6.2. Problem needs to be solved to allow DSG to access to the licenses and work proactively