

## DSG-SoLID Magnet Controls Meeting Minutes

**Date:** August 4, 2021

**Time:** 11:00 – 12:00

*Attendees: Aaron Brown, Peter Bonneau, Pablo Campero, Brian Eng, George Jacobs, Tyler Lemon, Marc McMullen, and Whit Seay*

### 1. Completed drawings

*Mary Ann Antonioli and Pablo Campero*

1. A00000-16-03- 0262 *JTV Motor Drives Wiring Diagram*
2. A00000-16-03- 0305 *PLC Relay Module, Remote A, Slot 5 Wiring Diagram*
3. A00000-16-03- 0313 *PLC Relay Module, Remote B, Slot 3 Wiring Diagram*

### 2. Modification for drawings in progress

*Mary Ann Antonioli and Pablo Campero*

1. A00000-16-03-0301 *PLC Relay Module, Remote A, Slot 1 Wiring Diagram*
2. A00000-16-03-0312 *PLC Relay Module, Remote B, Slot 2 Wiring Diagram*
  - Need to show connection node numbers for current lead heaters and sorb heaters, after creating wiring diagram for them
  - Will research specifications and pinout of sorb heaters' temperature controller
3. A00000-16-03-0403 *Radial Support Load Sensors Cable Diagram*
  - Defining cable colors for wires
  - Determining number and type of terminal strip to be used
  - Assigning labels for terminal strips
4. A00000-16-03-0404 *Axial Support Load Sensors Cable Diagram*
  - Defining cable colors for wires
  - Determining number and type of terminal strip to be used
  - Assigning labels for terminal strips
5. A00000-16-03-0350 *Power Supply Terminal Strips*
  - Need to confirm number and ampacity of circuit breakers required to protect 24 VDC and 5 VDC power supply circuits
6. A00000-16-03-0100 *Instrumentation Control Panel - Rear Layout*

### 3. Cables for SoLID magnet instrumentation

*Pablo Campero, Brian Eng, and Marc McMullen*

1. Updated *Cable List* spreadsheet
  - Added specifications for cables for strain gauges and load cell sensors
  - Eight cables added to the list
  - Added delivery dates for recent three cables delivered to Physics storage building
2. Reviewing voltage input specifications of Dataforth signal conditioning modules that will be used for voltage tap readout
  - Reviewed transient input protection rating code ANSI/IEEE C37.90.1. in ANSI-IEEE standard issued in 2002
  - Need access to the most current standard issued; working with Tim Fitzgerald
3. Delivered 20 AWG, 18-conductor cable (100 ft) to the Physics storage building
  - Cable (rated for 600 V) connects voltage tap signal readouts from the terminal strip to the Dataforth signal conditioning module
  - Required 20'; 80' leftover to be used in another application

4. Delivered 24 AWG, 8-conductor cable (100 ft) to the Physics storage building
  - Connects macro sensors output or transmitter (EBV8) to 12-position switch (for local readout of valve position) and PLC terminal strip to MCR relay terminals
  - Required 50'; 50' leftover
5. Delivered 24 AWG, 2-conductor cable (200 ft) to the Physics storage building
  - Connects macro sensor output voltage to 12-position switch, PLC terminal strip to key switch, PLC terminal strip to PLC terminal block terminals, and terminal strip to MCR connector for contacts
  - Required 100'; 100' leftover
6. Researching available ferrules for single and multi-connections, and ferrule crimper
  - Ferrules be purchased
    - For 20–24 AWG single and double conductors
    - For 16 AWG single and double conductors