

Magnets

- Eighteen interlock checkouts for Pre-Power-up of Torus completed.
- Start-up mode changed for Sol-LV-cRIO to allow an automatic program-run after the cRIO controller is power-cycled.
- Battery replaced and tested on the UPS of Torus power supply.
 - ★ Battery discharged < 20 seconds instead of lasting ~27 minutes for present load.