

## Hall D Controls Meeting 07-Feb-2019

**Date: 02/07/19**

**Time: 10:00am**

*Attendees: Peter Bonneau, Pablo Campero, Hovanes Egiyan, Brian Eng, Amanda Hoebel, Vanik Kakoyan, Tyler Lemon, Nick Sandoval, Justin Stevens, Tim Whitlatch*

### 1. General:

- 1.1. Hall is scheduled to close this afternoon.
- 1.2. Beam is scheduled for tomorrow.

### 2. Solenoid status:

- 2.1. Solenoid was ramped to 300A.
- 2.2. Is refilling after refrigerator maintenance.
- 2.3. Alarms will be cleared after levels rise above 40%.

### 3. DIRC controls:

- 3.1. Environment variable readouts are double the actual values.
- 3.2. Alarms are on bar boxes and optical flow.
  - 3.2.1. Alarms to be added for leak detector and air flow switch for Hall D group.
  - 3.2.2. Alarms to be added for temperature, humidity, and light sensor for DIRC group.