

## Hall D Controls Meeting 02-May-2019

**Date: 05/02/19**

**Time: 10:00am**

*Attendees: Peter Bonneau, Pablo Campero, Hovanes Egiyan, Brian Eng, Amanda Hoebel, Tyler Lemon, Nick Sandoval, Scot Spiegel, Tim Whitlatch*

### 1. General:

- 1.1. Next week, DSG will work on PXI.
- 1.2. UPS failed during power outage on April 22.
  - 1.2.1. All servers on UPS were rebooted.
  - 1.2.2. Some PLCs did not reconnect to network when power came back on.
- 1.3. Cables will be installed for VME crate remote reset.

### 2. Solenoid status:

- 2.1. Solenoid warmed to 80K for refrigerator maintenance.
- 2.2. Vacuum alarms on PLC disabled for magnet warm-up.

### 3. ComCal:

- 3.1. New air-cooled chiller ordered to replace old chiller.
  - 3.1.1. Due to arrive in June.
- 3.2. Tentative plan to install detector in the fall.

### 4. DIRC controls:

- 4.1. Liquid level sensors tested for optical box.
- 4.2. Window scheduled to arrive in mid-May.
  - 4.2.1. Installation scheduled for June.
- 4.3. Need temperature readout from FPGA board to be put in EPICS.