


# Solenoid Magnet Status Report

Pablo Campero

Detector Support Group

# DSG STAFF



# Contents

- Programming tasks
- Instrumentation tasks
- Documentation
- Upcoming tasks
- Conclusion




# Programming tasks

- PLC Program: controls and monitors the entire Solenoid in conjunction with cRIO and EPICS systems.
  - Consists of 11 main programs that comprise 72 routines.
    - Written on RS-Logix-5000 version 27.0.
    - Solenoid program was based on the Torus control program.
    - But several programs were modified and added with a new control logic.
  - Main control of the PLC were programmed to control:
    - Cool-down operations.
    - Magnet Energization- Ramp Down/Ramp Up.
    - Vacuum monitoring.
    - Solenoid Interlock system.
    - Cool-Down Interlocks system.
- Completed on 12/15/16




# Programming tasks

## Solenoid PLC program



11 main programs



72 Routines

# Programming tasks

- cRIO Programming

- Solenoid-LV-cRIO (Tyler Lemon)

- Programming based on Torus-LV-cRIO control program.
    - But it was modified according to Solenoid magnet needs.

- cRIO programmed to perform the following control operations:

- Set excitation voltage and current for different types of sensors that send data to the LV-Chassis.
    - Readout sensors data from solenoid magnet:
      - ✦ Cernox and PT 100 temperature sensors
      - ✦ Load Cells
      - ✦ Hall Sensors
    - Send data readout to the Solenoid PLC.

- Program updated to LabVIEW 2016 version.

- Completed on 02/28/17



# Programming tasks

- cRIO Programming

- Solenoid Fast DAQ cRIO programming (Tyler Lemon)

- Programming based on Torus-Fast-cRIO control program
    - But modified according to Solenoid magnet requirements.
    - Programed to perform the following control operations:
      - ◆ Acquire data from the Voltages Taps in the Solenoid Magnet
      - ◆ Scale data according requirements.
      - ◆ Send readout data to the Solenoid PLC controller at 5 [Hz].
      - ◆ Send readout data to EPICS systems at 10 [KHz].

- Program updated to LabVIEW 2016 version.

- Completed on 01/25/17



# Solenoid Instrumentation - Tasks


- Solenoid Vacuum System control design
  - Use 24 VDC power source to main vacuum gate Pneumatic Valve PV8600.
    - Isolated Rhino 24V power supply – 3.75 A, 90 W was assigned.
  - Instrumentation to monitor vacuum signals:
    - CG8606 main vacuum gauge → PLC Analog input module (0-10 V)
    - CG8600TB gauge → PLC Analog input module (0-10 V)
    - TB8600 Turbo Pump speed → PLC Analog input module (0-10 V)
    - PV8600 valve position → PLC Digital input module (0-31.2 V DC)
  - Clean 110 VAC power used for Vacuum instrumentation (pumps and hardware controllers)
  - Solenoid P&ID diagram corrected with the proper signal names updated on January 2017.
- Completed on 11/20/16.






# Solenoid Instrumentation - Tasks

- Solenoid Vacuum System hardware controllers



# Solenoid Instrumentation - Tasks

## Solenoid P&ID Vacuum System



## 4 Signals Monitored by Solenoid PLC

CG8606 - Main vacuum gauge

PV8600 - Valve position

CG8600TB - Vacuum gauge

TB8600 - Turbo Pump speed



# Solenoid Instrumentation - Tasks

- Solenoid cRIO grounded
  - Torus Fast DAQ cRIO presented high levels of noise in the readout Voltage Tap data.
  - As part of the noise prevention in the data acquisition for the Solenoid Voltage Tap, a ground wire was run from the chassis of Solenoid Fast DAQ cRIO to the control Rack.
  - Levels of noise did not decrease after grounding.
  - Noise problem continues being investigated
    - Possible solution: implement hardware filter




Mindy, Mary Ann and Sahin grounded Sol- FastDAQ-cRIO



# Solenoid Instrumentation - Tasks


- Solenoid Fast DAQ cRIO chassis grounded to the Solenoid control rack



# Solenoid Instrumentation - Tasks

Solenoid P&ID latest version issued on 26/01/17

Temp Sensors on relief Valves added



Vacuum signals modified

Local Heaters on Leads added

4.5K SUPPLY ORANGE  
 4.4K-3.9K SUPPLY BLUE  
 SHIELD CYAN

MAGNET  
 OPERATING TEMPERATURE: 4.4K-3.9K  
 OPERATING PRESSURE: 1.2-0.9 ATM  
 COOLDOWN MAX: 3 g/sec  
 STEADY STATE MAX: 1 g/sec

DATE	REVISION	DESCRIPTION	DATE	APPROVED
15APR16	1	ISSUE FOR CONSTRUCTION		D. KASHY
02	2	ADDED PNB673A		
03	3	ADDED FUTURE SUB-ATMOSPHERIC SYSTEM, REMOVED SUB-ATMOSPHERIC SYSTEM, CV 2 WAS 0.7, NOW 3.0.		
04	4	CHANGED HEATER WAS 'HT', NEW 'HTP'.		
05	5	ADDED HEL LEAD FLOW INSTRUMENTS.		
06	6	CHANGED SUB-ATMOSPHERIC FROM 'F.O.' TO 'F.C.'		
07	7	ADDED TP8673		
08	8	ADDED TP8611		
09	9	ADDED TP8610		
10	10	ADDED CV8678P		
11	11	ADDED F 16677B		
12	12	ADDED HTR8621C, HTR8621D, HTR8621E, HTR8621F, TCR8621G, TCR8621D, TCR8621E AND TCR8621F		
13	13	CHANGED RV8620A TO 1-1/2 X 2. 2.7 ATM		
14	14	MOVED SV8678P		
15	15	CHANGED RV8620A TO 1-1/2 X 2. 3.4 ATM		
16	16	CHANGED RV8620A TO VENT TO ATMOSPHERE		
17	17	ADDED SV8678P		
18	18	DELETED CT / PT8677B (LOCAL)		
19	19	ADDED SV8678		
20	20	ADDED RELIEF PRESSURE W/ & NO. GUARD VACUUM FOR PNB670.		
21	21	CHANGED TCR8620 TO 068001B.		
22	22	REVISED VACUUM PUMP SCHEMATIC. SEE COMMENT		

AREA	SIGNATURE	DATE	REVISION	DATE
APPROVED - SOLENOID INTEGRATION	J. HOGAN			
APPROVED - MAGNET INTEGRATION	A. FAIR			
APPROVED - CLASS 12 PROJECT INST	L. EDWARDS			
APPROVED - CLASS 12 PROJECT INST	C. BOVE			



# Solenoid Instrumentation - Tasks

- Solenoid Service Tower (SST) Instrumentation Test
  - Instrumentation Test PLC-EPICS Plan spreadsheet generated.
    - Document contains detailed information and procedures to perform the test.
    - Objectives of the plan test were:
      - ◆ Check hardwiring, hardware configurations, controllers and monitoring systems.
      - ◆ Ensure correct readout of the sensors in PLC controller and EPICS system.
    - Instrumentation tested specified on the spreadsheet
      - ◆ Not all sensors and instrumentation were tested, due that Helium flow is required.
    - Readout values of the instrumentation tested were recorded.
    - Section of comments to point future correction and improvements on the solenoid control system were added.
- Completed on 02/27/2017.



# Solenoid Instrumentation - Tasks


- Instrumentation Test PLC-EPICS Plan spreadsheet

INSTRUMENTATION TEST PLC- EPICS PLAN												
SOLENOID SERVICE TOWER - SST												
Signal ID	Sensor Type	Calibrated - Tested	Installed	To be tested Now	To be Tested after	Action	Check	Set Point	ReadBack Controller	ReadBack PLC	ReadBack EPICS	Comments
TR8622A	Cernox	Yes	Yes	Yes		1. Verify hardwiring - Use reference DWG 0649 & 0678	√	Temp Room ~ 300 [K]	293.982	293.551	293.55	
TR8622Ar		Yes	Yes			2. Check sensor connection in the Cryocon unit - Use Cryocon maps	√		293.982	293.551	293.55	
TR8622B		Yes	Yes			3. Unplug DB9 connectors except sensor that is being checked in rear panel of Cryocon 1	√		294.418	293.987	239.99	
TR8622Br		Yes	Yes			4. Verify if sensor position correspond to the channel assigned	√		294.418	293.987	239.99	
TR8611		Yes				5. Check communication between 490-NBX module and PLC	√		clip	0	0	
TR8611r		Yes				6. Verify correct read-back values for the sensor in the PLC controller	√		clip	0	0	
TR8672		Yes				7. Check communication between PLC and EPICS	√		clip	0	0	
TR8672r		Yes				8. Use the Helium SST EPICS screen to verify and monitor the temperature sensor readings in [K] units	√		clip	0	0	Cryocon1 unit at Channel F has set an "Internal_Temp" sensor connected
TR8671		Yes				9. Record Read-back values - compare PLC and Cryocon Readings	√		clip	0	0	
TR8671r		Yes				10. Repeat the steps above with each temperature sensor	√		clip	0	0	
TR8610		No							clip	0	0	
TR8610r		No							clip	0	0	
TR8670		Cernox	Yes				Yes			1. Verify hardwiring - Use reference DWG 0649 & 0678	√	Temp Room ~ 300 [K]
TR8670r	Yes			2. Check sensor connection in the Cryocon unit - Use Cryocon maps	√	clip		0		0		
TR8673	Yes			3. Unplug DB9 connectors except sensor that is being checked in rear panel of Cryocon2	√	clip		0		0		
TR8673r	Yes			4. Verify if sensor position correspond to the channel assigned	√	clip		0		0		
TR8674	Yes			5. Check communication between 490-NBX module and PLC	√	clip		0		0		
TR8674r	Yes			6. Verify correct read-back values for the sensor in the PLC controller	√	clip		0		0		
TR8624A	Yes			7. Check communication between PLC and EPICS	√	clip(blinking)		0		0	Cryocon2 unit at Channel D has set an "Not assigned" (Internal Temp) sensor connected	
TR8624B	Yes			8. Use the Helium SST EPICS screen to verify and monitor the temperature sensor readings in [K] units	√	clip(blinking)		0		0		
TP8621A	PT- 100	Yes				9. Record Read-back values - compare PLC and Cryocon Readings	√		clip	0	0	
TP8621Ar		Yes				10. Repeat the steps above with each temperature sensor	√		clip	0	0	
TP8621B		Yes							clip	0	0	
TP8621Br		Yes							clip	0	0	



# Solenoid Instrumentation - Tasks

- Solenoid Service Tower was moved to Hall B on December 15th , 2016.




Instrumentation – EV valves

Data sensor Cables

Vessel- Solenoid Service Tower

Provisional platform

Lead connectors





# Solenoid Instrumentation - Tasks

- Solenoid Service Tower (SST) Instrumentation Test

—The following sensors and instrumentation were tested on the SST

- Cernox temperature sensors. – total 20
  - ♦ Additional test perform in the Cryocon units 1,2 and 3.
- PT-100 Temperature sensors. - total 16
- Pressure transducers – total 2
- Differential Pressure transducers – Total 2
- LVDTs - Lineal variable differential transducers – Total 4.
  - ♦ Additional configuration made in DIP switches was required.
- Valves
  - ♦ Electric Valves EV – Total 4
  - ♦ Pneumatic valve PV- Total 1

- Completed on 02/27/2017.



# Solenoid Instrumentation - Tasks


- Solenoid Service Tower (SST) Instrumentation Test



Cernox and PT-100 Temp Sensors Read by the Cryocon units


Differential Pressure Transducers

Pressure Transducers



EV Valves

PV Valve



# Solenoid Instrumentation - Tasks

- Solenoid Service Tower (SST) Instrumentation Test
  - PLC control programs and routines associated with the instrumentation were tested.
    - PID Loops run as expected.
    - Configuration and scale factors (Engineering units) on the PLC were verified.
  - Issues regarding to the control hardwiring for the instrumentation on SST were solved
    - Input signal for Pneumatic Valve 8674 was changed.
      - ◆ Signal changed from analog PLC module to Relay output module.
      - ◆ Swapped air connector for valve.
    - PLC relay module was replaced (1 channel burned due wrong wiring).
      - ◆ Reassigned proper channel for OPEN JT86 relay output signal.
      - ◆ Tested 24 V DC relay output to all signals Open/Close for the EV valves.
  - Correction of the solenoid controls drawings and documentation related
    - DWG B00000900-0640, 0623 and 0626 were updated.
- Completed on 02/27/2016.



# Solenoid Instrumentation - Tasks

- Solenoid Service Tower (SST) Instrumentation Test
  - EPICS Screens were tested
    - Communication between PLC and EPICS was tested.
    - Solenoid Helium SST screen readouts for all the sensors and valves responded as expected.
      - ◆ Contributed to correct valve indicator for valve PV8674.
      - ◆ Noticed differences to get into PID controls screens for heaters.
    - Tested functionality of the PID control screens used to set the values to control OPEN/CLOSE for the EV valves.
      - ◆ Tested Manual Mode.
      - ◆ Verified stability and response for the valves at 50 percent open.


EV8611CD control PID screen

EV8611CD		
<b>Control Status</b>		
Current Value	50.92 %	
Mode	MANUAL	
<b>Manual Mode (Override)</b>		
Mode Request	MANUAL	MANUAL
Setpoint	50.00	
Current Value	50.92 %	
<b>Normal Mode (PID)</b>		
Input		
PV Name	PT8620	
PV Setpoint	0.00	
PV Measured	-1.78	
Output		
PID Output	50.93 %	
Current Value	50.92 %	
<b>PID Limits/Parameters</b>		
Max Value	0.00	0.00 %
Min Value	0.00	0.00 %
Max Change	0.00	0.00 %
Min Change	1.50	1.50 %
Sample Time	0.00	0.00 s
P - Gain	0.00000	0.00000
I - Gain	0.00000	0.00000
D - Gain	0.00000	0.00000



# Solenoid Instrumentation - Tasks

- Solenoid Helium – SST Screen used to perform Test.



# Solenoid Documentation –Tasks

- Solenoid Cooldown Documentation

- 1. B00000000901-P011 Hall B Solenoid System Cryogenics, Pre-Cooldown Instrument Checkout Procedure.

- ◆ Provide a general procedure for verifying ‘sensible’ readouts of cryogenic instruments prior to cooldown and to make available a location to record the results of the same.

- Completed on 02/16/17

- 2. B00000402-S001 Hall B Magnet and Cryogenic Control


- ◆ Describes the main control systems and sensors implemented in the Solenoid Magnet .

- Completed on 03/20/17



# Solenoid Documentation –Tasks

## —Solenoid Magnet and Cryogenic Control Diagram Updated



# Solenoid Documentation –Tasks

- Solenoid Pre-Power Up Documentation
  - 3. B000000400-P005 Hall B Solenoid Pre-Pre-Power-Up Interlock Checkout procedure.
    - ◆ Describes steps to perform interlocks checks before energization of the magnet.
- Completed on 02/16/17
  - 4. B000000400-P003 Hall B Solenoid Pre-Power-Up Instrument Checkout Procedure.
    - ◆ Describes a general procedure for verifying ‘sensible’ readouts of instruments prior to energization.
- Completed on 02/13/17





# Upcoming Solenoid Tasks

- Expected delivery for the Solenoid Magnet to JLab has been shifted to **May 9<sup>th</sup> 2017**.


—Reason for delay:

- During the load transfer of the coils to the cryostat vacuum jacket at the end of January, several components of the suspension system broke.
- This was caused by the steel parts for the support system not being made according to the mechanical drawings.

—Once the magnet arrives the following tasks will be performed by Hall B and magnet group ( to be completed ~ 6 weeks after delivered)

- Location and installation of the magnet in the Hall B.
- Welding of main structure and line components of the Solenoid
- Wiring of the sensors and instrumentation related.

Solenoid Suspension Components



# Upcoming Solenoid Tasks


- DSG group will be involve in the next tasks:
  - Full test of the PLC control program
  - Test cRIO low voltage LabVIEW program
  - Test cRIO Fast DAQ LabVIEW program
  - Complete instrumentation test on the SST
  - Test Instrumentation and sensors of the Solenoid magnet
  - Perform Pre-power up Interlocks checklist procedure.
  - Perform Solenoid System Cryogenics, Pre-Cooldown Instrument Checkout Procedure.
  - Fix problems related to acquisition data – [In progress](#)
    - Based on the current problems presented on the Torus magnet
      - ♦ Tested hardware filter to the Voltage Tap signals that will be added on the Solenoid.
      - ♦ Solution to avoid problem of readout 350 K error on the Sol-LV-cRIO is being investigated.



# Conclusion

- DSG contributed to:
  - Developing programs for PLC and cRIO controllers
  - Improving the control and monitoring systems
  - Testing Instrumentation
    - Hardware and wiring verification
    - Configuration of controllers, sensors and instrumentation .
  - Documenting control systems and procedures.
  - Solving discrepancies with technical documentation.





Thank you

