



Hall C CAEN SY4527 High Voltage System Test Results


Pablo Campero
Detector Support Group
November 6th, 2019

Content

- SY4527 Communication Modes
- List of Tests Performed
- Test Results
- Conclusions

Overview - SY4527 Communication Modes

- EPICS client → EPICS server
- LabVIEW client → EPICS server
- GECO 2000 host → GECO CPU
- Xterm → SSH secure shell-CPU



Communication modes to control and monitor CAEN SY4527 System
 Highlighted squares show components tested



Tests Performed

1. Overall communication test
2. Manual voltage ramp up/down test via EPICS client
 - Tested A1535 and A7030TN boards
3. Manual voltage ramp up/down test via SSH
4. Automated voltage ramp test with GECO 2020
5. Stability test with GECO 2020 and EPICS Client

Test 1. Communication Test

- Developed EPICS-CSS BOY screens and EPICS Client to test communication status for each HV board and mainframe
- Results
 - Able to read/write all PVs one by one
 - EPICS commands verified connection status that each PV works
 - Generated screens for each board and mainframe shows all PVs connected
 - **Found discrepancies between EPICS PVs and CAEN GECO/ssh**

Primary Power Supply Status		
Description	Set	Readback
Power Supply Current	1.44A:1.72A:0.	1.44A:1.72A:0.
Power Supply Voltage	0	0

Network Status		
Description	Set	Readback
IP ADDRESS	129.57.86.124	129.57.86.124
IP NET MASK	255.255.255.0	255.255.255.0
IP GATEWAY	129.57.86.1	129.57.86.1

Network setting controls available from CSS-EPICS screen developed

TEST HV CAEN - Expert Controls - Slot 2																	
Novice		Board Model		A7030TN - [S/N: 324]										ALL ON/OFF			
Ch#	Location	Click to Turn	Status	VMon [V]	Imon [uA]	Vset [V]		Iset [uA]		Vmax [V]		RUp [V/s]		RDwn [V/s]		Trip [s]	
						Readback	Set	Readback	Set	Readback	Set	Readback	Set	Readback	Set	Readback	Set
00	DSG-Lab	OFF	ON	1499.90	-0.020	1500.00	1500	1000.00	1000.00	1800	1800	25	25	25	25	3.0	3.0
01	DSG-Lab	OFF	ON	1499.85	-0.004	1500.00	1500	1000.00	1000.00	1800	1800	25	25	25	25	3.0	3.0
02	DSG-Lab	OFF	ON	1499.80	-0.082	1500.00	1500	1000.00	1000.00	1800	1800	25	25	25	25	3.0	3.0
03	DSG-Lab	OFF	ON	1499.76	0.944	1500.00	1500	1000.00	1000.00	1800	1800	25	25	25	25	3.0	3.0
04	DSG-Lab	OFF	ON	1499.68	-0.082	1500.00	1500	1000.00	1000.00	1800	1800	25	25	25	25	3.0	3.0
05	DSG-Lab	OFF	ON	1499.92	-0.008	1500.00	1500	1000.00	1000.00	1800	1800	25	25	25	25	3.0	3.0
06	DSG-Lab	OFF	ON	1499.90	-0.052	1500.00	1500	1000.00	1000.00	1800	1800	25	25	25	25	3.0	3.0
07	DSG-Lab	OFF	ON	1499.77	-0.078	1500.00	1500	1000.00	1000.00	1800	1800	25	25	25	25	3.0	3.0

CSS-BOY expert control screen used to test HV boards


```
[campero@dsg-b-linux1 ~]$ cainfo hvcaentest2:00:000:Pw
hvcaentest2:00:000:Pw
State:          connected
Host:          129.57.86.124:5064
Access:        read, write
Native data type: DBF_ENUM
Request type:  DBR_ENUM
Element count: 1
[campero@dsg-b-linux1 ~]$
```

Linux Host PC with EPICS base showing connection status for PVs

Test 2. EPICS Client Voltage Test

- Used EPICS Client (CSS-BOY screens) to control and monitor parameters (V_{Mon} , I_{Mon} , V_{OSet} , I_{OSet} , V_{RUp} , V_{RDWn} , $Trip$, SV_{Max} , and Pw)
 - Used GECO 2020 interface to verify CSS-BOY screen's PVs
- Results
 - **Random channels did not turn on**
 - **Pre-set values for some parameters changed randomly during test**
 - **Discrepancies between values shown in GECO 2020 and PVs read from CAEN EPICS Server**

Test 2. EPICS Client Voltage Test




Channel 2 changed $V_{RU\dot{p}}$ value from 25 V/s to 1 V/s

Initial set SV_{Max} parameter changed from 1800 V to 1 V and channel 31 tripped
Channel 28 changed $V_{RDW\dot{n}}$ value from 25 V/s to 1 V/s

Expert Controls CSS-EPICS screen developed to monitor voltage ramps for all 36 channels of A7030TN module

Test 3. Voltage Test via Secure Shell Connection

- Used ssh xterm interface to control and monitor HV board parameters
 - For verification used GECO 2020 and EPICS Client interfaces
- Results
 - Pre-set values for some parameters did not change randomly during the test
 - Parameters between GECO 2020 and ssh interface matched
 - **Discrepancy with PV values read from CAEN EPICS Server via EPICS client (CSS-BOY screens)**



The screenshot shows a terminal window titled '1. admin@hvcaentes2'. The terminal displays a table of parameters for 'Group 01'. The table has columns: Channel Name, TripInt, TripExt, ImAdj, BdStatus, HVMax, HIMax, and Ch#. The data rows show 'DSG-Lab' channels with various current values (e.g., 1.000 uA, 0.000 uA, 3.000 uA) and voltage limits (3148 V, 1118 uA). The status is consistently '0' and 'BdStatus' is '3148 V'. At the bottom, it says 'Display/Edit Group 01' and 'LocEn V0 I0 T | CAEN SY4527'. A footer link is provided: 'MobaXterm by subscribing to the professional edition here: <http://mobaxterm.mobatek.net>'.


Channel Name	TripInt	TripExt	ImAdj	BdStatus	HVMax	HIMax	Ch#
DSG-Lab	0	16	1.000 uA	3148 V	1118 uA	00.0000	
DSG-Lab	0	16	0.000 uA	3148 V	1118 uA	00.0001	
DSG-Lab	0	16	0.000 uA	3148 V	1118 uA	00.0002	
DSG-Lab	0	16	1.000 uA	3148 V	1118 uA	00.0003	
DSG-Lab	0	16	0.000 uA	3148 V	1118 uA	00.0004	
DSG-LAB	0	16	0.000 uA	3148 V	1118 uA	00.0005	
DSG-LAB	0	16	0.000 uA	3148 V	1118 uA	00.0006	
DSG-LAB	0	16	1.000 uA	3148 V	1118 uA	00.0007	
DSG-LAB	0	16	0.000 uA	3148 V	1118 uA	00.0008	
DSG-LAB	0	16	0.000 uA	3148 V	1118 uA	00.0009	
DSG-LAB	0	16	0.000 uA	3148 V	1118 uA	00.0010	
DSG-LAB	0	16	3.000 uA	3148 V	1118 uA	00.0011	
DSG-LAB	0	16	0.000 uA	3148 V	1118 uA	00.0012	
DSG-LAB	0	16	0.000 uA	3148 V	1118 uA	00.0013	
DSG-LAB	0	16	0.000 uA	3148 V	1118 uA	00.0014	
DSG-LAB	0	16	0.000 uA	3148 V	1118 uA	00.0015	
DSG-LAB	0	16	0.000 uA	3148 V	1118 uA	00.0016	
DSG-LAB	0	16	0.000 uA	3148 V	1118 uA	00.0017	
DSG-LAB	0	16	0.000 uA	3148 V	1118 uA	00.0018	

MobaXterm ssh interface terminal shows board's parameters that are controlled

Test 4. Automated Test


- Test performed with single A7030TN board connected
 - Tested all 36 channels 100 times at 1500 V
 - Used GECO 2020 to run script for auto voltage ramp up/down cycles, to control and monitor and log parameters
 - Included status parameter to previous list (slide 6)
 - Used EPICS client to only monitor test
- Results
 - None of 36 channels' parameters for each tested board changed
 - CSS-BOY screens matched with GECO 2020 in the latency issues found
 - **EPICS commands and PV updates for P_w parameter did not update**
 - **Random 8 s — 10 s latency to ramp up some channels during some cycles in the test**

Test 4. Automated Test



GECO 2020 data shows latency to ramp up channel 11

Test 4. Automated Test




GECO 2020 data logged plot shows relation between *VMon*, *Pw* and *Status* parameters during a ramp up/down cycle when latency incident was present

Test 5. Stability Test

- Test ran for > 24 hours to check for random changes of pre-set values
 - Tests performed with a single or 16 A7030TN boards connected
 - Tested with all 36 channels at 0 V and 1500 V
 - Only used GECO 2020 to control, monitor, and log all 16 boards' parameters
- Results
 - None of 36 channels' parameters for each tested board were changed
 - Random voltage spikes of ~ 236 V, even when *V0Set* was set at 0 V
 - Possibly a readout voltage spike at software level (not real)
 - Issues with changing all channel's (x576) parameters
 - *SVMMax*, *VSet*, and *IMax* at the same time with GECO 2020

Test 3. Stability Test



Zoomed-in view of Voltage Ramp Test CSS-BOY screen shows a 2 s voltage spike for channel 27

Voltage Ramp Test CSS-BOY screen shows voltage spikes during stability test run with a single board

Test 5. Stability Test

- Results

- GECO 2020 data matched PV values shown by Voltage Ramp Test CSS-BOY screen
- No changes in set values for all monitored/set parameters
- Voltage monitored was set point $1500\text{ V} \pm 0.3\text{ V}$, and current monitored $\sim 0\text{ }\mu\text{A}$ as expected (no load connected for test)
 - Both monitored parameters within CAEN specifications



Plot shows zoomed-in view of channels 0 to channel 11; voltage set at 1500 V

Conclusions

- Discrepancies and random changes are present when EPICS client is used to control and monitor **(Page 7)**
- Latency issues in random channels was seen even when only GECO 2020 is used to control and monitor **(Page 10)**
- During stability test noticed, random voltage spikes ~ 230 V **(Page 13)**
- Completed software test for one mainframe and 17 A7030TN boards
 - Detailed reports sent to CAEN support
 - Test will continue on remaining 19 boards and 1 mainframe to be delivered to JLab on December, 2019.

THANK YOU