

# NI 9871 Module Testing Progress Report

Aaron Brown  
Detector Support Group  
August 21, 2019

# Contents


- Overview
  - Module being tested: NI-9871
- Technical Specifications
- Tests
  - LabVIEW code
- Problems Faced
- Moving Forward
- Conclusion

# NI-9871

- 4-Port RS485/RS422

## Serial Module

- Used in conjunction with  
NI USB-to-485 4-Port  
Serial Interface Device



# Technical Specifications

	NI-9871	NI USB-485
Type	4-Port RS485 Serial Module	USB-to-RS485 Serial Interface
S/N	1A71D6E	1A3FAC6
Max Baud Rate	3686.4 kbps	460.8 kbps
Voltage Range	8-28 VDC	9-30 VDC

Both module and USB-485 are connected to their own 24 VDC power supplies.

# Tests

- Read/write capability tests
  - Can module read from USB-485 and write back to it? ✓
  - Are there any special characters that this module cannot handle?
  - Does this module read back *exactly* what has been written to it?
  - Does this module write *exactly* what it has been instructed to write?
- Test different baud rates (in development)


# Read/Write Test: Block Diagram

Open serial session for USB-485 and NI-9871


Flushes read and write buffers

Module read buffer should match COMM BUFFER: WRITE exactly.

Flat sequence structure ensures that serial session for the module closes before the serial session for the USB-485



# Read/Write Test: Front Panel



LabVIEW front panel for NI-9871 serial module test. User changeable port selection and baud rate. Read and write buffers, and error messages.

# Problems Faced

- Ethernet cable
  - Module requires RJ-50 cable, but only RJ-45 cables available.
  - Solution: Purchased RJ-50 cable.
- Serial cable adapter
  - To connect module to USB-485 serial interface via Ethernet cable an adapter was needed that could support an RJ-50 Ethernet cable.
  - Solution: Purchased breakout board and DB9 serial adapter.



# Problems Faced (cont'd)

- Read/write
  - Could not read from either USB-to-serial interface or module in National Instruments Measurement & Automation Explorer (NI MAX), but could write from both.
  - Solution: Changed timeout from 2 s to 4 s on both module and USB-485 serial interface. This appears to have fixed timeout error.
- Baud rates
  - Unsuccessfully attempted to increase rates (from 9600 bps to 14400 bps) for both module and USB-485. Only worked for USB-485.
  - Maximum baud rate for module is significantly higher than that of USB-to-485, so there is a limit to how high it can be tested.

# Moving Forward

- Decide how many times to run each test.
- Determine how to change baud rate for module.
- Test different baud rates, create random string generator, and compare read/write strings.
- Determine if these tests are enough to ensure that module works according to manufacturer's specifications.

# Conclusions

- The NI-9871 serial module behaves as it should under these specific conditions:
  - Baud rate of 9600 bps
  - Only for specific characters input for test

**Thank You!**