

**HV-EPICS Test Station Status Report**  
**August 14, 2019**

*DSG Staff: Pablo Campero, Peter Bonneau, and Marc McMullen*

1. Generated CAEN-SY4527 Test Results Power Point presentation
2. Calculated resistor value to be used in the load box, which will allow current test for CAEN-7030TN, A7435, and A1535 HV boards via developed CSS screens.

CAEN Board Model	Max Voltage [V]	Max Current [mA]	Max Power [w]	Selected Resistor [K $\Omega$ ]	Max Voltage with Standard Resistor [V]	Max Power with Standard resistor [w]	Max Current with Standard Resistor [mA]
A1535	3500	3	8	2000	2200	2.42	1.1
A7435SN	3500	3.5	9	2000	2300	2.65	1.15
A7030TN	3000	1	1.5	2000	1720	1.48	0.86

3. Selected and ordered 38 Through Hole Resistor, 2 Mohm, Slim-Mox Series, 2.5 W,  $\pm 1\%$ , Radial Leaded, 20 kV.
4. Verified firmware version for hvcaentest1 CAEN mainframe
  - 4.1. PV and web server indicated version as 2.0.1
5. To continue with the debugging of hvcaentest2 mainframe CAEN software issues:
  - 5.1. Contacted CAEN representative to request firmware version 2.0.1 and enable the downgrade hvcaentest2 mainframe from its actual version 2.0.2 to version 2.0.1.
  - 5.2. CAEN representative informed that the soonest to get firmware version is for next week.
6. Conducted a meeting to present result for CAEN SY4527 systems tested and discuss about status of EPICS/Hardware test station developed by DSG and upcoming work.
7. For the development of an automated test for CAEN-SY4527 system, downloaded and installed CSS-Scan Server on dsg-b-linux1 PC.