

TO: MEMORANDUM TO FILE

DATE: March 14, 2012

SUBJECT: Facility Readiness for Safe Operations and Occupancy

The "Facility Readiness for Safe Operations and Occupancy" report dated 14 March 2012 documents the TED Building is ready for occupancy except for the minor items noted. The TLA is on track for occupancy in accordance with the Life Safety Code. Final inspection and testing of the fire alarm, sprinkler systems, fire barriers and fire doors, exit signs, and emergency lighting will be necessary. The interim safety devices are adequate for initial occupancy.



Dave Kausch, JLab Fire Protection Engineer

Concurrence:



Richard Korynta, Federal Project Director